

HVAC Metal Bellows Copper End Axial Expansion Joints

Specification

Copper ended with 316 stainless steel bellows intended primarily for HVAC water applications – LTHW, heating and drinking water. WRAS approved.

Materials

- Ends Copper BS EN1057 Table 'X'
- Bellows 316 stainless steel

Rating

6 Barg @ 90 °C

Approvals



Size	Length	Axial Comp.	Axial Ext.	Copper pipe size
in.	mm	mm	mm	mm
DN012-½"	220	25	0	15
DN020-¾"	230	25	0	22
DN025-1"	235	25	0	28
DN032-1¼"	245	25	0	35
DN040-1½"	250	25	0	42
DN050-2"	250	25	0	54

